

CALIFORNIA DEPARTMENT OF FORESTRY & FIRE PROTECTION
OFFICE OF THE STATE FIRE MARSHAL
FIRE ENGINEERING - BUILDING MATERIALS LISTING PROGRAM

LISTING SERVICE

LISTING No. 7167-1574:185 Page 1 of 1

CATEGORY: Control Unit (Household)

LISTEE: ADT Security Services, Inc., 695 Route 46 West, Suite 200, Fairfield, NJ, 07004-1561
Contact: Ron Dalton (310) 725-2972 FAX (310) 725-2942

DESIGN: Model SW-EZ9P combination fire and burglary alarm control unit and Model SW-EZTPAD boltypad keypad. The keypad is provided with a built in PIR and Sounder. Refer to listee's data sheet for detailed product description and operational considerations.

RATING: 10-12.5 VDC

INSTALLATION: In accordance with listee's printed installation instructions, applicable codes and ordinances and in a manner acceptable to the authority having jurisdiction. The system must have the secondary power supply capable of operating the system for at least 24 hours (battery standby) in the normal condition and followed by not less than 4 minutes of alarm as required by code.

MARKING: Listee's name, model number, electrical rating and UL label.

APPROVAL: Listed as household fire and burglary alarm control units for use with separately listed compatible initiating and indicating devices.

These control units do not generate the distinctive three-pulse Temporal Pattern Fire Alarm Evacuation Signal (for total evacuation) as required per NFPA 72, 1999 Edition. If required, they must be used with indicating signaling appliances that can produce the temporal code pattern. Refer to listee's Installation Instructions Manual for details.

NOTE:

1. Burglary and other non-fire functions of this control unit were not examined.
2. Fire Alarm Verification feature (delay of fire alarm) shall NOT be used in residential applications in California.
3. Formerly 7167-0085:201

XLF: 7167-0992:128

05-20-2004



This listing is based upon technical data submitted by the applicant. CSFM Fire Engineering staff has reviewed the test results and/or other data but does not make an independent verification of any claims. This listing is not an endorsement or recommendation of the item listed. This listing should not be used to verify correct operational requirements or installation criteria. Refer to listee's data sheet, installation instructions and/or other suitable information sources.

Date Issued: **JUNE 23, 2004**

*Listing Expires **June 30, 2005***

Authorized By: **DIANE K. AREND, Senior Deputy
Program Manager**